



NOTE: INSTALL SADDLE PRIOR TO DRILLING FOR THE TAP

METER BOXES: NON TRAFFIC AREAS SHALL BE CHRISTY N36 WITH STEEL CHECKER PLATE LID. TRAFFIC AREAS SHALL BE H-20 RATED CHRISTY B1730 WITH STEEL CHECKER PLATE LID. LIDS SHALL HAVE HOLES TO ACCOMMODATE FLEX NET SENSOR.

BRASS USED IN MANUFACTURING SHALL COMPLY WITH THE LATEST AWWA STANDARDS FOR WATER WORKS BRASS, SUCH AS ANGLE CHECK VALVES, ANGLE VALVES, QUARTER BENDS, ETC.

METERS: WATER METERS SHALL REGISTER IN GALLONS AND BE SENSUS OMNI C2 WITH FLEX NET SENSOR INSTALLED THROUGH LID. METERS SHALL BE BROUGHT TO THE DISTRICT OFFICE FOR REGISTRATION. METERS ARE NOT TO BE INSTALLED IN THE METER PITS.

METER BOX INSTALLATION: METER BOXES SHALL BE INSTALLED IMMEDIATELY ADJACENT TO THE PROPERTY LINE ON THE STREET SIDE. THERE SHALL BE NO POSSIBILITY OF ENCLOSURE BY PROPERTY OWNER'S FENCE. WITHIN EACH METER BOX AN IDENTIFICATION TAG SHALL INDICATE THE ADDRESS THE METER SERVICES.

SERVICE LINE PIPING: SERVICE LINE PIPING IS ALL PIPE WHICH IS INSTALLED BETWEEN THE MAIN WATER LINE AND THE METER BOX. THIS PIPING SHALL BE IRON PIPE SIZE (IPS) (200 PSI), MADE OF POLYETHYLENE MATERIAL IN ACCORDANCE WITH AWWA C-901 AND SHALL MATCH THE METER SIZE.