



NOTES:

1. CONCRETE BOXES SHALL BE TRAFFIC RATED UTILITY BOX CHRISTY B1730 OR EQUAL.
2. BRASS USED IN MANUFACTURING SHALL COMPLY WITH THE LATEST AWWA STANDARDS FOR WATER WORKS BRASS, SUCH AS ANGLE CHECK VALVES, ANGLE VALVES, QUARTER BENDS, ETC.
3. ALL MATERIALS IN CONTACT WITH POTABLE WATER SHALL BE NSF 61 CERTIFIED.
4. CORP STOP, PIPE, AND ANGLE VALVE DIAMETER ALL TO MATCH AIR VALVE SIZE.

POLYETHYLENE RISER (IPS)—INSTALL W/ CONSTANT UPWARD SLOPE FROM CORP STOP TO ANGLE VALVE

